N - L I N E S O L I D S / L I Q U I D S

Separators

In-Line Separators for **Industrial Applications**

Use our centrifugal-action separator to remove grit, sand, metal chips, fines, and other solids from liquids. Perfect for use as a pre-filter to extend the life of fine filtration systems. These units require little or no maintenance, as there are no moving parts to wear out, or filter media to replace. The unit only requires a simple purging, eliminating downtime. For flows from 6 gpm and retention ratings to 50 micron.

How it works:

Fluid enters the pressure vessel tangentially at high velocity. A centrifugal action is created, which forces the solids to separate and enter the sump, while the clean liquid exits up through the standpipe. The solids collect in the sump, and can easily be purged. The operation is so simple, it can be set to automatically purge on a timed interval.

Features

- Low constant pressure drops
- Piped housings
- Carbon steel or stainless steel (304 or 316) construction for housings
- All housings are electropolished to resist adhesion of dirt and scale
- ASME code stamp available
- Pipe sizes 3/8 through 10-inch (larger sizes also available)

Options


- Different outlet connections
- Special materials

Typical Applications


- Cooling towers
- Process water
- Food processing
- Chemical processing
- Well water
- Pulp & paper mills
- Mining operations
- Steel mills
- Petrochemical industry
- Power plants
- Protection of spray nozzles and other small orifices
- Chip removal from cutting coolants
- Car and vehicle wash systems
- Paint spray booths
- Heat exchangers
- Spray nozzle protection
- Industrial laundries
- Solids recovery
- Parts washing systems
- Pump protection
- Domestic Water
- Recirculating cooling water
- Sprinkler systems
- Quench water
- Pre-filter for seawater


IN-LINE SOLIDS/LIQUIDS SEPARATORS

FLOW RANGE – GPM								
Model No.	Pipe Size (inch)	5 PSID	10 PSID	Inlet/ Outlet	Drain Size (inch)			
SEP-6	3/8	3	6	NPT	1			
SEP-11	1/2	7	11	NPT	1			
SEP-25	3/4	15	25	NPT	1			
SEP-35	1	30	40	NPT	1			
SEP-75	1-1/4	55	75	NPT	1			
SEP-80	1-1/2	60	80	NPT	1			
SEP-130	2	90	130	NPT	1			
SEP-140	2-1/2	96	140	NPT	1			
SEP-275	3	200	275	NPT or Flanged	1			
SEP-553	4	425	553	Flanged	2			
SEP-1265	6	985	1265	Flanged	2			
SEP-2210	8	1715	2210	Flanged	2			
SEP-3410	10	2640	3410	Flanged	2			



Specific Gravity of Various Materials									
Material Specific Gravity	Material Specific Gravity								
Aluminum 2.7	Graphite 2.3								
Ashes (Coal) 2.0	Iron 7.8								
Brass 9.0	Lead 11.3								
Bronze/Copper 8.9	Limestone 2.8								
Carbon/Concrete/Lava 1.8-2.5	Manganese 7.4								
Coal (Anthracite) 1.3-1.9	Nickel 8.9								
Earth (Silt/Soil) 1.2-2.0	Sand/Silica/Shale 2.6-2.8								
Glass (Crystal) 3.0	Steel 7.8								
Granite/Gravel 2.5-3.0	Tin Ore 6.4-7.0								





Separator Sizing:

Separators are generally sized so that there is at least a 5 PSID pressure drop across the unit. Separation efficiency increases as pressure drop increases. We've shown flow ranges for each unit based on 5 and 10 PSID. Choose a unit based on a flow/efficiency balance.

IN-LINE SOLIDS / LIQUIDS SEPARATORS

Installation

The Separator should be installed in a near vertical position. The unit should be supported by means other than the inlet/outlet piping. First, connect the outlet of the unit to the outlet piping. Then install any supports, such as U-bolts or legs. Next, connect the inlet piping to the inlet. Test for leaks and separation. The unit is now ready for operation.

Purging and Maintenance


Separators must be purged regularly. If they are not, the separated solids will accumulate and overflow the collection area, affecting performance and contaminating effluent.

You can manually, automatically, or continuously purge the collection area of the separator. Manual purging requires that the operator open a simple valve and empty the contents. Automatic purging can be done many different ways, but the simplest is setting a timer to open and close the valve, purging the contaminant on a regular basis. Continuous purging simply requires leaving a manual valve partially open at all time, letting the contaminant leak out at a controlled rate. For best results, all purging should be done while the separator is in operation. Avoid purging "uphill" which will result in buildup and clogging, affecting performance and operation.

Simple rules of maintenance include checking the purge valve regularly for clogging, scale, and buildup. If the unit is installed in an area where the ambient temperature is below freezing, the collection area and all purge piping should be kept from freezing while operating. If left in idle state under freezing conditions, the entire unit must be drained of liquid, and the collection area must be purged of solids.

Dimensions (IN)

Model	Α	В	C	D	E
SEP-6	3.0	14.8	4.5	1.9	.6
SEP-11	3.0	14.8	4.5	1.9	.6
SEP-25	4.5	17.2	8.6	3.5	1.1
SEP-35	4.5	23.6	8.6	3.5	1.1
SEP-75	4.5	23.5	8.6	4.5	1.4
SEP-80	4.5	23.5	8.6	4.5	1.3
SEP-130 (2		22.6	8.6	6.6	2.1
SEP-140 (2		22.6	8.6	6.6	1.9
SEP-275	6.6	25.2	10.7	8.6	2.6
SEP-553	13.	45.2	18.0	12.7	4.1
SEP-1265	16.4	58.0	24.0	16.0	4.7
SEP-2210	21.0	67.2	24.0	16.0	4.7
SEP-3410	21.7	105.6	42.0	30.0	8.0



Build an ordering code as shown in the example

